

TRANSFORMER OIL DATA SHEET
Standard Oil Analysis

DATE : 10/25/2006
CUSTOMER : HVES
CIRCUIT/LOCATION : HVES #31
MANUFACTURER : Howard Industries
KVA/TYPE or M/N : 2000
S/N : 483653806

<u>TEST</u>	<u>ASTM</u>	<u>LIMITS*</u>	<u>RESULTS</u>
WATER CONTENT	D1533	20 Max	: 5 ppm
INTER-FACIAL TENSION	D971	32 Min	: 39.7 Dynes/ppm
NEUTRALITY	D974	0.10 Max	: 0.004 mg KOH/g
COLOR	D1500	3.5 Max	: <0.5
VISUAL EXAMINATION	D1524	N/A	: Clear & bright
DIELECTRIC	D877	26 Min	: 50 kV
SPECIFIC GRAVITY	D1298	0.91 Max	: 0.876

*NETA Table 100.4.1 and ANSI/IEEE C57.106-2002 "Guide for Acceptance and Maintenance of Insulating Oil in Equipment," Table 7.

COMMENTS: